



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components for Automatic Sprinkler Systems (Expansion Shields)

<i>Product Designation</i>	<i>Hanger Rod Size, inch</i>	<i>Max Nominal Pipe Size, in.</i>
TruBolt+	3/8	4
TruBolt+	1/2	8
TruBolt+	5/8	12
TruBolt+	3/4	12

Prepared for:

ITW Commercial Construction North America
700 High Grove Blvd
Glendale Heights, IL 60143
United States

FM Approvals Class: 1952

Approval Identification: 0003053725

Approval Granted: February 16, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D. B. Fuller".

David Fuller
AVP - Manager of Fire Protection
FM Approval
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group