



Materials and Research Center
2300S.W. Van Buren Street
Topeka, KS 66611-1195

Richard Carlson, Secretary
Greg M. Schieber, P.E., Chief

Phone: 785-296-2231
Fax: 785-296-2526
Hearing Impaired - 711
kdot#publicinfo@ks.gov
<http://www.ksdot.org>

Sam Brownback, Governor

July 27, 2017

Guru Kumar
ITW Commercial Construction N.A.
700 High Grove Blvd.
Glendale Heights, IL 60139

Dear Mr. Kumar,


Per discussion with Mr. Daniel Banachowski we have evaluated your Red Head G5+ submittal for Types I and IV only. The product is compliant with the requirements for Types I and IV, Grade 3, Class B and C bonding systems of Section 1705 of the 2015 KDOT Standard Specifications. Because the gel time is less than 30 minutes, automated proportioning, mixing, and dispensing equipment is required. Here is a summary of the approval:

| <u>Product</u> | <u>Type</u> | <u>Grade</u> | <u>Class</u> |
|----------------|-------------|--------------|--------------|
| Red Head G5+ | I | 3 | B, C |
| | IV | 3 | B, C |

This product will be placed on the KDOT prequalified list PQL 10.5, "Epoxy-Resin-Base Bonding Systems for Concrete."

Please direct any questions to me at 785-368-6521.

Sincerely,



Richard Barezinsky, P.E.
Assistant Bureau Chief-Materials